

In-Sight Sample Projects Using a Mitsubishi GOT1000

THIS COGNEX SOFTWARE CONTAINS CERTAIN COMPUTER PROGRAMS AND OTHER PROPRIETARY MATERIAL OF COGNEX AND/OR ITS LICENSORS, THE USE OF WHICH IS SUBJECT TO THE SOFTWARE LICENSE AGREEMENT (THE "AGREEMENT") THAT ACCOMPANIED THIS DELIVERY. YOU AGREE TO BE BOUND BY THE TERMS OF THE AGREEMENT BY INSTALLING OR OTHERWISE USING THE COGNEX SOFTWARE. DO NOT PROCEED WITH THE INSTALLATION OF THE COGNEX SOFTWARE UNTIL YOU HAVE READ THE AGREEMENT AND AGREE TO BE BOUND BY AND BECOME A PARTY TO THE AGREEMENT. IF YOU DO NOT AGREE TO THE AGREEMENT TERMS, DO NOT INSTALL, USE OR COPY THE COGNEX SOFTWARE, AS YOU ARE NOT AUTHORIZED TO DO SO.

Overview

This document describes the sample applications installed with In-Sight explorer to show methods of using the Mitsubishi GOT to control and get results from an In-Sight vision system. In these examples, the user will select an inspection type from the main screen of the Mitsubishi GOT. The GOT will load an In-Sight job file from the In-Sight vision system.


Minimum Software Requirements

The table below lists the minimum software versions for Cognex and Mitsubishi software:

Software	Examples	Version
Cognex		
In-Sight Explorer	All	4.3
Mitsubishi		
GT Designer	All	2.92W
GX Developer	Ladder Logic	8.78G
GX Works2	Function Blocks	1.09K

System Setup

For these examples, the In-Sight vision system, GOT, PLC, and PC are connected to an Ethernet switch.



The following settings are used in the examples:

In-Sight:

IP Address: 192.168.0.1

Subnet Mask: 255.255.255.0

Telnet Port: 23 (default)

Q-Series PLC:

IP Address: 192.168.0.2

Subnet Mask: 255.255.255.0

GOT1000:

IP Address: 192.168.0.4

Subnet Mask: 255.255.255.0

The PLC and GOT files have the IP addresses in the projects. Loading the project files will update the IP addresses for the PLC and GOT. If necessary, change the IP Address and telnet port of the vision system through the Sensor→Network Settings or the System→Add Sensor/Device to Network menus.

Vision System Setup

In these examples, the user will use the controls on the GOT screen to acquire an image in In-Sight, perform an inspection, and send the results to the GOT. There are PDF files that can be used as samples for each of the inspections. The PDF files should be printed out and used with the In-Sight vision system. The PDF files are located in the following directory and described in the table below:

C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Part Images

Filename	Examples
xy and inspect.pdf	xy-en.job, inspect-en.job
IDCode.pdf	IDCode-en.job

Example setup:

This document provides an example of a lens, working distance and field of view to use with these printed PDF files. The field of view does not need to be exact because the PatMax tools and ReadID tools will tolerate changes in scale of the part.

The user can also retrain the PatMax models in the files xy-en.job, inspect-en.job and retrain the ReadID tool in IDCode-en.job to work with a different field of view. The jobs must be resaved to the In-Sight vision system to work properly with the GOT sample program.

Vision System: In-Sight Micro 1400

Lens: 8 mm c-mount lens with a 5 mm spacer

Working Distance: 280 mm (11 inches)

Field of View – 170 mm (approximately 6 ¾ inches)

Filenames and Locations

Cognex In-Sight Files:

There are three In-Sight job files that are used in the GOT control examples. The In-Sight files are located in the following directory, and described in the table below:

C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Control Examples\In-Sight Job Files

Filename	Examples	Purpose
xy-en.job	All	Returns X, Y, Angle
inspect-en.job	All	Returns Pass/Fail
IDCode-en.job	All	Returns QR Decode String

Mitsubishi Files:

The files to use for the specific model of GOT and PLC are described in the tables in this section.

The files to use for the Mitsubishi GOT depend on the model of GOT and PLC that you will use. The GOT files for the GT15 model are located in the following directory and described in the table below:

C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Control Examples\GOT Examples\GT15

GOT Model	GOT Screen Resolution	Filename
GT15	SVGA	GT15_SVGA_E71_EN.GTE GT15_SVGA_QnEDEH_EN.GTE

The PLC files to use depend on the model of PLC that you will use, and the method, ladder logic or function block. The Q Series PLC programs are located in folders within the directory below and descriptions are described in the table below:

C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Control Examples\GOT Examples

Filename	Example	Ethernet Port	SubDirectory
In-Sight_E71_Q06UDHCPU_EN	Ladder Logic	QJ7171-100	Ladder Logic
In-Sight_QnUDE_Q06UDEHCPU_EN	Ladder Logic	Q06UDEHCPU	
In-Sight_FB_E71_EN	Fuction Blocks	QJ7171-100	Function Block\Cognex_In-Sight
In-Sight_FB_QnUDEH_EN	Function Blocks	Q06UDEHCPU	

Loading Files

In-Sight Files

Save all three In-Sight job files, xy-en.job, inspect-en.job and IDCode-en.job to the In-Sight vision system. The GOT main screen will load the correct In-Sight job directly from the In-Sight vision system.

Q-Series PLC Files

Start GX Developer for ladder logic examples, and GX Works2 for function block examples.

Load the appropriate file for the CPU on your PLC. PLC files are located in the following directories:

For ladder logic:

C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Control Examples\GOT Examples\Ladder Logic

For function blocks:

C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Control Examples\GOT Examples\Function Block\Cognex_In-Sight

GOT Files:

Start GT Designer, and load the appropriate GOT file for your GOT model. Got Files are located in the following directory:

C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Control Examples\GOT Examples\GOT Files

Load the GT Designer file onto the GOT.

The GOT uses information stored in the file tagname.txt to communicate with the job files in In-Sight. This file should be stored on the compact flash (CF) card on the GOT.

Saving the tagname-en.txt file to the CF Card on the GOT

The file send_tagname.bat will send the files tagname-en.txt and tagname.txt to the CF card on the GOT at IP address 192.168.0.4. Run the send_tagname.bat in one of the following ways:

1. Locate the file in Windows Explorer in the following directory and double-click it:
C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Control Examples\GOT Examples\GOT Files
2. Run send_tagname.bat from a command prompt:
 - Run CMD.exe to open a command prompt
 - Change directory to **C:\Program Files\Cognex\In-Sight\In-Sight Sample Projects 4.3.0\Mitsubishi Communications\Control Examples\GOT Examples\GOT Files**
 - Run send_tagname.bat

Running the Example Files:

1. Put In-Sight Online.
2. Reset the PLC.
3. Put the PLC into Run mode.
4. Apply power to the GOT.

You can now control the In-Sight vision system using the GOT interface.